



To: Fence Installation Contractors

From: Derek Boulanger, Facilities Manager/ Purchasing Agent

Date: April 18, 2018

RE: Addendum to Bid #2018-016 "The Purchase and Installation of an All Black Vinyl Coated Chain Link Fence."

The following questions were received via e-mail and an addendum is hereby presented for the project:

1. Question: There is no information on the diameter, weight or length of pipe to be used on this project. This could lead to substantial differences in job cost and quality/longevity of the fence. Will this be clarified before the bid?

Answer:

All fence materials to be Black Vinyl Covered

All fence fabric to be #8-gauge Black Vinyl Covered

All fence piping to be SS40 and driven to a minimum depth of 4'

358 ft of 10-foot-high fence. To include 2.5-inch in line posts and 3-inch terminal posts

430 ft of 6-foot-high fence. To include 2-inch in line posts and 2.5-inch terminal posts.