

ADDENDUM NO. 2
TO
CITY OF AUBURN, MAINE
LAKE STREET RECONSTRUCTION PROJECT
June 26, 2017

This addendum amends and /or supplements the bid documents as indicated below. Only these items alter the bid documents. Any verbal discussions or responses are hereby declared null and void. Please acknowledge this addendum on the attached Bid Form.

Clarifications to the Bid Documents:

The following changes have been made to the Bid Documents:

Question: Is the curbing detail correct? This is not how the City typically specs out granite curb installation.

Answer: Granite curb shall be backfilled front and back with concrete up to HMA base course elevation.