

ADDENDUM NO. 1
TO
CITY OF AUBURN, MAINE
2018 RECLAMATION PROJECT
March 28, 2018

This addendum amends and /or supplements the bid documents as indicated below. Only these items alter the bid documents. Any verbal discussions or responses are hereby declared null and void. Please acknowledge this addendum on the attached Bid Form.

Clarifications to the Bid Documents:

The following changes have been made to the Bid Documents:

Updated Bid Form is attached. Note the addition to quantity of Item 304.14 for the placement of ¾” shoulder gravel for the LCP portion of Old Danville Road from Harmon’s Corner Road to South Main Street.

Attached mark up of construction limits.

Question: Are the gravel items measured in place or cubic yard truck measure?

Answer: Cubic yard truck measure.

Question: Is 1-1/2” minus A - Gravel specified for this project for the reclaim portion of the project.

Answer: Correct, the gravel placed in the reclaim section of this project is proposed as 1-1/2” minus A – Gravel. Note the grade matching shoulder gravel is ¾” minus as stated in the RFP on page 19 of 41.

Question: Is a mailbox group on one post paid as 1 for Item 606.10?

Answer: The Item 606.10 will be paid for each per post regardless of how many mailboxes are attached.

Question: Is Item 627.733 4” Yellow Pavement Marking paid as a single line or double?

Answer: This item is paid as a single 4” yellow line. So, for one linear foot of paved road, the Contractor is paid for 2 linear feet of Item 627.733 assuming a double yellow line placement.

Question: How is the South Main Street portion going to be constructed as to not create a jump for vehicles?

Answer: This portion is proposed as a reclaim and the limits of construction in this area will be determined in the field for proper transition.

Question: What item will the 1' shoulder gravel be paid under?

Answer: Shoulder gravel will be paid under Item 304.14.

Question: Who will be responsible for butt joints at the location of where the LCP portion is proposed, the Contractor or the State?

Answer: The LCP portion has yet to be scheduled. Item 202.203 Pavement Butt Joints will be used to pay for road pavement transitions.

Question: How will driveways be matched with the road?

Answer: Driveways shall be sawcut and pavement removed for matching. See Scope of Work in the RFP on page 9 of 41.

Question: What is the driveway build up and what item will the pavement be paid under?

Answer: See Scope of Work in the RFP on page 9 of 41. Hand placed pavement for driveways is paid under Item 403.209 Hand Work regardless of pavement size.

Question: What are the requirements for QC on machine placed pavement?

Answer: The following shall be added to Special Provision F-16 on page 14 of 41 of the RFP: The Contractor is required to perform their own QA/QC on gravels and pavements. Testing reports shall be submitted to the City.

Question: What is the budget for this project?

Answer: \$1,000,000.00

Question: Will the Contractor be held to the 2" spec on the reclaim material?

Answer: The City expects the Contractor to monitor behind the reclaimer to remove or regrind all large chunks of pavement.

Question: How will bituminous curb and driveway pavement removal be paid?

Answer: These material removals will be paid under Item 203.20 Common Excavation.

BID FORM

MDOT ITEM	DESCRIPTION	UNIT	QNTY	UNIT COST	TOTAL COST
202.201	Sawcut Pavement	LF	1,100		
202.203	Pavement Butt Joints	SY	80		
203.20	Common Excavation	CY	2,500		
203.24	Common Borrow	CY	500		
211.30	Ditch Excavation	LF	13,500		
304.10	Aggregate Subbase Course – Crushed Type D	CY	1,500		
304.14	Aggregate Base Course- Crushed Type A	CY	8,650		
304.141	Aggregate Base Course- Crushed Type A (Driveways)	CY	1,100		
307.32	Reclaim Existing Roadway	SY	20,000		
403.208	Hot Mix Asphalt, 12.5mm - Surface	TON	1,700		
403.213	Hot Mix Asphalt, 12.5mm - Base	TON	2,300		
403.209	Hot Mix Asphalt, Hand Work	TON	600		
409.15	Bituminous tack coat, applied	GAL	500		
603.15	12" Culvert HDPE Pipe	LF	600		
603.16	15" Culvert HDPE Pipe	LF	220		
603.19	24" Culvert HDPE Pipe	LF	180		
603.21	36" Culvert HDPE Pipe	LF	120		
603.22	48" Culvert HDPE Pipe	LF	60		
604.18	Adjust Existing Catch Basin to Grade	EA	2		
606.10	Adjust Existing Mailbox Post	EA	43		
609.31	Bituminous Curb Type 3	LF	1,100		
610.08	Plain Riprap	TON	300		
615.08	Loam, Seed & Mulch	SY	8,800		
620.54	Stabilization/Reinforcement Geotextile	SY	22,000		
627.733	4" Yellow Painted Pavement Marking Line	LF	15,800		
652.36	Work Zone Traffic Control	LS	1		
659.10	Mobilization	LS	1		
			TOTAL		

Written total amount is: _____

Company Name: _____

Signed by: _____

Title: _____

Print Name: _____

Address: _____

Tel. # _____

Date: _____


Addendum Acknowledged:

_____ Date _____

_____ Date _____




This map was created by the City of Auburn. While every effort has been made to ensure that these data are accurate and reliable, the City of Auburn cannot accept any responsibility for any errors, omissions, or positional inaccuracies, and therefore, there are no warranties which accompany this product. Users of the information displayed on this map are strongly cautioned to verify all information before making any decisions.





This map was created by the City of Auburn. While every effort has been made to ensure that these data are accurate and reliable, the City of Auburn cannot accept any responsibility for any errors, omissions, or omissions of liability accuracy, and therefore, there are no warranties which accompany this product. Users of the information displayed on this map are strongly cautioned to verify all information before making any decisions.





This map was created by the City of Auburn. While every effort has been made to ensure that these data are accurate and reliable, the City of Auburn cannot accept responsibility for any errors, omissions, or positional accuracy, and therefore, there are no warranties which accompany this product. Users of the information displayed on this map are strongly cautioned to verify all information before making any decisions.

0 100 200 Feet
1 inch = 100 feet

Document: C:\Users\kenneth\Desktop\Library\Ave.mxd Date Saved: 2/5/2018 Author: kenneth