

**ADDENDUM #1**

**Hasty Community Center Steam Boiler Replacement Project, Auburn, Maine**

**Bid No. 2014-017**

City of Auburn, Maine

29 October 2013

**Specification Items:**

Note: All changes to specification items will be in bold font and underlined.

1. Remove the Table of Contents, and insert the enclosed Revised Table of Contents.
2. Remove the Performance Specification, and insert the enclosed Revised Performance Specification.
3. Remove the Bid Proposal Form, and insert the enclosed Revised Bid Proposal Form. **Note: The revised form includes the addition of Addendum #1 with a date of 29 October 2013 as acknowledgement.**

**NOTE: THIS REVISED BID PROPOSAL FORM MUST BE USED WHEN SUBMITTING YOUR BIDS FOR THIS PROJECT TO ACKNOWLEDGE RECEIPT OF THE ADDENDUM.**

4. Remove the Schedule of Values, and insert the enclosed Revised Schedule of Values with an Add Alternate to convert the existing Propane (LP) fired generator to Natural Gas (NG).

**Drawing Items:**

Not used.

**Clarification Items:**

Not used.

**Attachments:**

1. Revised Table of Contents
2. Revised Performance Specification
3. Revised Bid Proposal Form
4. Revised Schedule of Values
5. Pre-Bid Meeting Minutes

**END OF ADDENDUM #1**

**Table of Contents**

CONDITIONS AND INSTRUCTIONS TO BIDDERS ..... 3  
GENERAL CONDITIONS ..... 4  
1. Equal Employment Opportunity ..... 4  
2. Save Harmless..... 4  
3. Subcontracting ..... 4  
4. Warranty ..... 4  
PERFORMANCE SPECIFICATION ..... 5-11  
BID PROPOSAL FORM..... 12  
SCHEDULE OF VALUES..... 13  
**ADDENDUM #1..... 14**

**PERFORMANCE SPECIFICATION**

PART 1 - GENERAL

1.1 RELATED DOCUMENTS

- A. Conditions and Instructions to Bidders
- B. General Conditions of the Contract

1.2 SITE INSPECTION AND TEMPORARY HEAT

- A. The mechanical contractor is required to make a pre-bid site visit in order to submit a bid on this project.
- B. The Mechanical Contractor is responsible to provide, install and test a temporary low pressure steam boiler to heat the building during construction. The boiler shall be a minimum heating input of 1,000,000 BTUH and be connected temporarily to the new 2 psig gas meter. During the switch-over from oil to the temporary gas boiler and then back to new gas boiler the heat can only be down for a maximum of 6 (six) hours.
- C. **The Mechanical Contractor may install the new gas boiler in a location within the mechanical room so that a temporary boiler is not needed and the switch-over from the existing oil fired boiler to the new gas boiler can be accomplished with a maximum down time of 6 (six) hours.**

1.3 SUMMARY

- A. This is a design-build mechanical project. The information provided in this specification is intended to communicate the preferences of the owner. It is the Mechanical Contractor’s responsibility to properly design, install, start/test, and warranty the replacement boiler system.
- B. The information provided in this section is intended to provide the minimum size, quantities and quality of material – it is the Mechanical Contractor’s responsibility to provide and install what the Mechanical Contractor believes to be the correct sizes and quantities.
- C. It is the Mechanical Contractor’s responsibility to design and install the systems per the following Codes and Standards:
  - 1. NFPA (National Fire Protection Association) Standards
  - 2. IECC 2009 (International Energy Conservation Code)
  - 3. American Gas Association (AGA)
  - 4. Applicable Town of Auburn Ordinances.
  - 5. Requirements of the State of Maine Gas Board Rules.
- D. The Mechanical contractor is responsible for all permit and application fees.

- E. The Mechanical Contractor is responsible to design and install a complete and operating heating system including, but not limited to:
  - 1. Removal and proper disposal of the existing oil boiler and burner, breechings and smoke pipe.
  - 2. Removal of the oil piping in the mechanical room that connects to existing boiler.
  - 3. Removal and proper disposal of all electrical power and control wiring that is not being reused.
  - 4. Removal of existing housekeeping pad under the boiler.
  - 5. Installation of a new gas-fired low pressure steam boiler.
  - 6. Installation of a new gas-fired hot water heater.
  - 7. Installation of chimney lining and boiler breeching.
  - 8. Installation of a vent for the new hot water heater.
  - 9. Installation of chimney condensate piping and neutralizer.
  - 10. Installation of new housekeeping pad for new boiler and new hot water heater.
  - 11. New natural gas piping from existing gas meter to the new burner and new hot water heater – 2 psig.
  - 12. Installation of new combustion air fan and repair of relief vent.
  - 13. All required electrical and power wiring to new hot water heater, new burner and combustion/heat relief fan.
  - 14. All required controls and control wiring to burners, combustion/heat fan, spill switches, low water cutoffs, condensate receiver pump and burners.
  
- F. Submit with your bid, a summary of your design including equipment manufacturers and existing equipment and material that you intend to reuse.

NOTE – OWNER HAS THE OPTION TO KEEP ANY OF THE REMOVED MATERIAL AND EQUIPMENT.

1.4 SUBMITTALS (if awarded contract)

- A. Submit shop drawings, manufacturers' data and certificates for equipment, materials and finish, and pertinent details for each system where specified.
  
- B. Review will be for type and quality. Quantities and the ability to perform the function intended shall be the responsibility of the Contractor.

PART 2 - PRODUCTS AND SYSTEMS

2.1 REMOVAL OF EXISTING SYSTEMS.

- A. Remove from job-site and properly dispose of all materials in the mechanical room that are not being reused.

- B. The Following is a list of the expected material that will be removed.
  - 1. One steam boiler/burner.
  - 2. Boiler breeching in mechanical room.
  - 3. Boiler smoke pipe.
  - 4. Existing boiler housekeeping pad
  - 5. Oil piping connected to the existing oil burner. Note – generator oil piping is to remain in use.
  - 6. Electrical power and control wiring.

## 2.2 GAS-FIRED STEAM BOILER AND BURNER

- A. New Boiler to be a HB Smith Model 28A-S-5 Pressurized Wet Base Boiler or equal Weil McLain boiler.
  - 1. 5 Section Boiler – 1,491 MBH IBR Capacity – Natural Gas.
  - 2. Cast Iron Wet Base.
  - 3. Insulated Metal Jacket.
  - 4. Front and rear flame observation ports.
  - 5. Steel angle floor rails.
  - 6. Manual reset hi-limit.
  - 7. Operating Control.
  - 8. ASME side outlet safety valve – 15 psi.
  - 9. Gauge glass with cocks and guard.
- B. Burner to be a Power Flame J50A-15 or equal Webster series JB burner.
  - 1. To be supplied with boiler as a package from the manufacturer.
  - 2. Low-High Burner operation.
- C. The new natural gas burner/boiler package shall comply with the Efficiency Maine Natural Gas Program, Measure Code G13, Natural gas-fired steam boiler >300 MBtu/h and ≤2,500 MBtu/h, Thermal Efficiency ≥79%.

## 2.3 BOILER ACCESSORIES

- A. Provide all the boiler accessories to make the boiler/burner Code Compliant including the requirements of the Maine State Gas Board.
- B. Provide a new dial type pressure gauge.
- C. The existing Pump Control – Low Water Control appears to be in good condition and can be cleaned and reused.

## 2.4 DOMESTIC HOT WATER HEATER

- A. New Domestic Hot Water Heater to be AO Smith Cyclone gas-fired hot water heater Model Number BTH 150 or approved equal that meets the following specification.
  - 1. **95 % thermal efficiency – 150,000 BTUH input.**
  - 2. 100 gallon capacity tank.
  - 3. 247 GPH at a 70 deg. temperature rise.
  - 4. 3” PVC Sealed combustion – vent and combustion air.

## 2.5 CHIMNEY LINING AND BREECHINGS

- A. Provide Chimney Linings and Connections to the New Boiler. Lining to extend up through the existing masonry chimney. Remove brick “legs” on roof and top cap. Fabricate a flashing to cover chimney opening. New Chimney Lining must extend at least 36” above roof.
- B. Chimney Lining and Breaching material to be manufactured by Metal-Fab or Van Packer.
- C. Size chimney per manufacturer’s recommendations.
- D. **All Lining, Connections, Fittings and Breeching to meet the following material specification. Metal Fab or Van Packer equivalent.**
  - 1. **UL Listed for Category III Furnace/Boiler.**
  - 2. **Breeching shall be double wall with 1” air space.**
  - 3. **Liner shall be single wall.**
  - 4. **Temperature rating 1,000 degrees continuous.**
- E. Linings, Connections, Fittings and Breeching to include:
  - 1. Chimney Lining.
  - 2. Termination at roof.
  - 3. Tee at base of chimney with condensate connection.
  - 4. Horizontal breeching to boilers with condensate connection at low point.
  - 5. Barometric damper.
  - 6. Transition to boiler flue outlets.

## 2.6 HOT WATER HEATER VENTING

- A. **Provide and install a solid core PVC to the outside, size per the manufacturers recommendations. (possibly through the existing chimney space outside the new liner). Install per NFPA 54 Requirements and terminate the vent per manufacturer’s requirements.**
- B. The combustion air does not need to be vented to the outdoors.

## 2.7 CONDENSATE PIPING

- A. Install condensate piping for the chimney at the base of chimney, and any low points in the breeching as recommended by the chimney manufacturer. Pipe condensate to nearest floor drain.
- B. Install a condensate neutralizer approved by or provided by the boiler manufacturer in the condensate line before the drain.

## 2.8 STEAM AND CONDENSATE PIPING

- A. Reuse of the existing piping is allowed.
- B. Any new steam piping to be Schedule 40 Black Iron. Any new condensate piping to be Schedule 80 Black iron.
- C. Insulate all steam piping, condensate receiver tank, and condensate piping within the mechanical room with 1-1/2" fiberglass insulation with ASJ. Fittings to be Zeston or approved equal.

## 2.9 DOMESTIC HOT WATER PIPING AND MAKE-UP BOILER WATER

- A. Connect the new domestic hot water heater to the existing domestic hot water system.
- B. Reconnect the boiler make-up water.
- C. Piping to be Type L Copper.
- D. Insulate new hot water piping with 1" fiberglass insulation with ASJ. Fittings to be Zeston or approved equal.
- E. All work to be done by a licensed plumber per the Uniform Plumbing Code.

## 2.10 GAS PIPING

- A. The existing gas meter is a 2 PSIG natural gas.
- B. **Run Schedule 40 black iron from the existing meter to the new boiler and hot water heater. Provide TEE and shut-off valve; capped for future connection to the existing generator.**
- C. Provide drip leg and shutoff at all connections.
- D. Paint all the gas piping Yellow. – Clean, prime and final coat of Rustoleum Yellow. Mark piping every 20' with "2 psig Natural Gas" – Seton Manufacturing Company Labels or approved equal.
- E. The New Hot Water Heater will require a 2 psig to 7" w.c. regulator at the burner. A vent limiting regulator is acceptable.
- F. The contractor is to size the gas piping per NFPA 54 Standards and the requirement of the Uniform Plumbing Code.

## 2.11 COMBUSTION AIR AND HEAT CONTROL FAN

- A. Cap the existing combustion air intake on the bottom of the existing intake duct

- B. Add a Greenheck SE Propeller Supply Fan, or approved equal, in the intake configuration in order to pressurize the boiler room. Mount the fan on the existing combustion air ductwork.
  - 1. 1350 cfm at 0.125" esp.
  - 2. With backdraft damper.
  - 3. With OSHA Motor side guard.

## 2.12 HOUSEKEEPING PADS

- A. Provide and install a new concrete housekeeping pad for the new boiler/burner and hot water heater. **Install to meet applicable American Concrete Institute International standards.**
- B. Pad to be a minimum of 3-1/2" thick and extend at least 3" in all directions from the boiler/burner and domestic hot water heater.

## 2.13 POWER ELECTRICAL WIRING

- A. It is the Mechanical Contractors responsibility to provide all power wiring to the new Boiler, Hot Water Heater, Combustion/heat fan, boiler safety controls and line voltage thermostat. This work must be done by a licensed electrician.
- B. The Thermal Control Limit sensors above the boiler will need to be moved to the highest part of the room over the boilers. Run new wiring in EMT conduit.
- C. Installation to meet NFPA 70 National Electrical Code Standards.

## 2.14 CONTROL AND CONTROL WIRING

- A. Provide control for the boilers and hot water heater.
- B. All exposed control wiring in the boiler room to be run in EMT Conduit.
- C. Use of the existing serviceable wiring and controls is acceptable.
- D. Add to the barometric damper a spill switch to stop burner operation if a down draft is detected. Tjerlund Products Safety interlock system or approved equal.
- E. Add a line voltage cooling thermostat (adjustable) to energize the new propeller intake fan on a call for mechanical room cooling.
- F. Energize the new propeller fan any time the new gas burner on the boiler is operating.

## 2.15 MISCELLANEOUS WORK

- A. **Repair the existing motorized louver on the boiler room wall.**

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. Perform work by qualified journeymen of their respective trades who are employed by a firm that can demonstrate successful experience with work similar in type, quality and extent to the work required by this project.
- B. Install mechanical equipment to facilitate maintenance and repair or replacement of equipment components. As much as practical, connect equipment for ease of disconnecting, with minimum of interference with other installations.
- C. Cutting and Patching: Protect the structure, furnishings, finishes, and adjacent materials not indicated or scheduled to be removed.
- D. Operation and Maintenance Data: Provide manufacturer's printed operating procedures to include start-up, break-in, routine and normal operation instruction; regulation control, stopping, shut-down, and emergency instructions; and summer and winter operation instructions. Provide copies of warranties.
- E. Provide owner with a one year warranty on all parts and labor. Provide the owner with the standard warranties from the boiler manufacturer.

**BID PROPOSAL FORM**  
**Due Thursday, October 31, 2013**

To: City of Auburn  
Derek Boulanger,  
Facilities Manager/Purchasing Agent  
60 Court Street  
Auburn, ME 04210

The undersigned individual/firm/business guarantees this price for Thirty days (30) from the bid due date. The undersigned submits this proposal without collusion with any other person, individual, firm, or agency. The undersigned ensures the authority to act on behalf of the corporation, partnership, or individual they represent; and has read and agreed to all of the terms, requests, or conditions written herein by the City of Auburn. By signing this bid form, the firm listed below hereby affirms that its bid meets the minimum specifications and standards as listed above **and as amended in Addendum #1, dated October 29, 2013.**

Signature \_\_\_\_\_ Name (print) \_\_\_\_\_

Title \_\_\_\_\_ Company \_\_\_\_\_

Address \_\_\_\_\_

Telephone No. \_\_\_\_\_ Fax No. \_\_\_\_\_

Email Address: \_\_\_\_\_

STATE OF MAINE  
\_\_\_\_\_, SS.

Date: \_\_\_\_\_

Personally appeared \_\_\_\_\_ and acknowledged the foregoing instrument to be his/her free act and deed in his/her capacity and the free act and deed of said company.

\_\_\_\_\_  
Notary Public

\_\_\_\_\_  
Print Name  
Commission Expires \_\_\_\_\_

**SCHEDULE OF VALUES**

PROJECT NAME: **Hasty Community Center Steam Boiler Replacement Project –  
Bid #2014-017**

**CONTRACTOR SCHEDULE OF VALUES**

<u>Item</u>	<u>Description</u>	<u>Value</u>
1.	General Conditions	\$ _____ . _____
2.	Bonds & Insurance	\$ _____ . _____
3.	Demolition	\$ _____ . _____
4.	Boiler & Accessories	\$ _____ . _____
5.	Natural Gas Piping	\$ _____ . _____
6.	Hydronic & Condensate Piping	\$ _____ . _____
7.	Insulation	\$ _____ . _____
8.	Domestic Hot Water	\$ _____ . _____
9.	Electrical & Fans	\$ _____ . _____
10.	Controls	\$ _____ . _____
11.	Chimney Lining	\$ _____ . _____
12.	Other (specify) _____	\$ _____ . _____
13.	Other (specify) _____	\$ _____ . _____
14.	Other (specify) _____	\$ _____ . _____
<b>15.</b>	<b><u>TOTAL BASE BID (Sum of Items 1 thru 14)</u></b>	<b>\$ _____ . _____</b>
<b>A.</b>	<b><u>ADD ALTERNATE #1</u></b>	
	<b><u>Convert Existing Generator from LP to NG</u></b>	<b>\$ _____ . _____</b>

**TOTAL OF ALL LINE ITEMS IN SCHEDULE OF VALUES MUST EQUAL FINAL BASE BID.**

**THERE MUST BE AMOUNTS IN EACH OF THE SPECIFIED ITEMS ABOVE.**

**FAILURE TO PROPERLY COMPLETE THIS ATTACHEMENT WILL BE CONSIDERED A NON RESPONISVE PROPOSAL AND WILL BE REJECTED.**

<b>Project:</b>	City of Auburn, Maine – Hasty Community Center Steam Boiler Replacement Project	<b>Date:</b>	October 24, 2013
<b>Project No.:</b>	CCPG #725	<b>Bid No.:</b>	2014-017
<b>Meeting:</b>	Pre-Bid Meeting	<b>Time:</b>	9:00 a.m.
<b>Location:</b>	Hasty Community Center, Auburn, Maine		

<u>Attendees</u>	<u>Company</u>	<u>E-Mail</u>
Derek Boulanger	City of Auburn, Facilities Manager/Purchasing Agent	<a href="mailto:dboulanger@auburnmaine.gov">dboulanger@auburnmaine.gov</a>
Mitch Daigle	Cordjia Capital Projects Group, LLC	<a href="mailto:mdaigle@cordjiacpg.com">mdaigle@cordjiacpg.com</a>
Kurt Magnusson	Mechanical Systems Engineers	<a href="mailto:kurt@mechanicalsystemseng.com">kurt@mechanicalsystemseng.com</a>
Mark Morin	Nason Mechanical	<a href="mailto:mmorin@nasonmechanical.com">mmorin@nasonmechanical.com</a>
Mark Bouchard	Nason Mechanical	
Gary Perry	Sullivan & Merritt Constructors	<a href="mailto:gperry@sullivanandmerritt.com">gperry@sullivanandmerritt.com</a>
Roger Berryment	Engineered Construction Services, Inc.	<a href="mailto:rberryment@ecsincorp.com">rberryment@ecsincorp.com</a>
Travis Wheeler	Mechanical Services Inc.	<a href="mailto:twheeler@mechanicalservices.com">twheeler@mechanicalservices.com</a>

**Copy of Meeting Minutes sent to: Attendees Names listed above.**

1.	<p>Bid opening will be at 2:00 pm on October 31, 2013 at 60 Court Street, Auburn, Maine. Bids must be delivered and stamped received prior to 2:00 pm on October 31, 2013.</p> <p>All bid questions and RFI's must be submitted in writing to both Mr. Mitch Daigle of Cordjia Capital Projects Group ("Cordjia") and Mr. Derek Boulanger of the City of Auburn ("COA") prior to 9:00 am on October 29, 2013. Email will be accepted but it is the responsibility of the contractor to confirm that the email correspondence has been received.</p> <p>Addendums and clarifications will be issued to the contractor's email addresses that were provided on the pre-bid sign in sheet. The contractors should ensure that whoever this email address belongs to knows to distribute the addendums and clarifications to the correct person. It only has to be proven that it was received, and cannot be verified how it gets distributed after it is received. Please allow read receipts for emails.</p> <p>The BID PROPOSAL FORM, is part of any addendum and will have the addendum number and date pre-filled on the form. <b>This updated bid proposal form must be used when submitting a bid.</b></p>
2.	<p>Points of contact are as follows:</p> <p><u>Technical Inquiries:</u> Mr. Mitch Daigle - Cordjia; Office: 207-236-9970; Mobile: 207-333-2226; Email: <a href="mailto:mdaigle@cordjiacpg.com">mdaigle@cordjiacpg.com</a></p> <p><u>Bidding Inquiries &amp; Access to the Building:</u> Mr. Derek Boulanger – City of Auburn; Office: 333-6601, ext. 1135; Email: <a href="mailto:dboulanger@auburnmaine.gov">dboulanger@auburnmaine.gov</a></p>

<b>Project:</b>	City of Auburn, Maine – Hasty Community Center Steam Boiler Replacement Project	<b>Date:</b>	October 24, 2013
<b>Project No.:</b>	CCPG #725	<b>Bid No.:</b>	2014-017
<b>Meeting:</b>	Pre-Bid Meeting	<b>Time:</b>	9:00 a.m.
<b>Location:</b>	Hasty Community Center, Auburn, Maine		

ID	Discussion / Remark
3.	Contractor shall provide a copy of all certificates of insurance with limits pursuant to the City of Auburn’s requirements prior to commencing the work.
4.	<p>For contract awards greater than \$100,000.00 the successful Bidder will be required to furnish 100% contract Performance Bond and a 100% contract Payment Bond to cover the execution of the Work.</p> <p>If the bid proposal is less than \$100,000 then the line item for Bonds &amp; Insurance on the Schedule of Values can be indicated as \$0.00 for Bonds.</p>
5.	Permits are the contractor’s responsibility for their scope of work and shall be included in the bid. The authority having jurisdiction shall be contacted for verification of any applicable permitting requirements and engineered designs.
6.	Designated parking, storage, and mobilization areas will be further discussed prior to construction with the selected contractor.
7.	<p>The selected contractor is expected to start the work once a notice of award has been issued and complete the work as soon as practical in order to satisfy the City’s needs.</p> <p>Each contractor shall include their anticipated commencement and completion dates in their bid package for review by the City of Auburn.</p>
8.	Submit with your bid a summary of your design including equipment manufacturers and existing equipment and material you intend to reuse.
9.	This project is subject to compliance with all requirements of the Occupational Safety and Health Administration (OSHA), Volume 36, No. 105 of the Federal Register, U.S. Department of Labor published Saturday, May 29, 1971, as amended.
10.	It will be the contractor’s responsibility for the proper disposal of all construction waste.
11.	The Owner reserves the right to salvage any existing equipment; however, the Owner does not anticipate requesting salvage of any equipment on this project.

<b>Project:</b>	City of Auburn, Maine – Hasty Community Center Steam Boiler Replacement Project	<b>Date:</b>	October 24, 2013
<b>Project No.:</b>	CCPG #725	<b>Bid No.:</b>	2014-017
<b>Meeting:</b>	Pre-Bid Meeting	<b>Time:</b>	9:00 a.m.
<b>Location:</b>	Hasty Community Center, Auburn, Maine		

ID	Discussion / Remark
----	---------------------

12.	<p>Work conditions &amp; clarifications:</p> <p>The contractor shall continuously maintain adequate protection of all work from damage and shall protect the property from injury or loss for the duration of this contract, and shall make good any such damage, injury or loss.</p> <p>The Owner's business operations must continue throughout the entire construction period.</p> <p>The selected contractor will be provided a building use/occupancy schedule prior to the start of construction.</p> <p>Contractors will have access to the site between 7:00 AM and 6:00 PM. The Owner may provide special access on late weekdays, weekends, and holiday's but this will be by special request with a minimum of 48 hours advance notice and approval by the Owner.</p> <p>The selected contractor will be provided secure access to the work area. This will be discussed in further detail with the selected contractor prior to construction.</p> <p>No utility cutoff (if required) will be permitted without 3 days advance notice and approval by the Owner.</p> <p>No construction debris not immediately contained in a proper disposal container will be tolerated at any time during the duration of this project.</p> <p>Smoking and tobacco products are allowed on the building grounds provided it occurs a minimum of 25 feet from the building. Waste must be properly disposed of and taken off-site.</p> <p>Heating must be provided to the building at the end of each work day.</p> <p>The new natural gas piping from the meter into the mechanical room shall be sized to allow for future conversion and connection of the existing 35 KW propane fired generator.</p> <p>The exhaust from the new domestic hot water heater can be ducted into the existing chimney flue if desired provided that the construction of the flue is per the manufacturers recommendations for this condition and the installation is pursuant to code.</p> <p>The contractor may select an appropriate location for the new domestic hot water heater provided that the location is per the manufacturer's recommendations and the installation is pursuant to code.</p>
-----	---

<b>Project:</b>	City of Auburn, Maine – Hasty Community Center Steam Boiler Replacement Project	<b>Date:</b>	October 24, 2013
<b>Project No.:</b>	CCPG #725	<b>Bid No.:</b>	2014-017
<b>Meeting:</b>	Pre-Bid Meeting	<b>Time:</b>	9:00 a.m.
<b>Location:</b>	Hasty Community Center, Auburn, Maine		

ID	Discussion / Remark
----	---------------------

	<p>The new domestic hot water heater will require a new mixing valve and expansion tank that is installed pursuant to code.</p> <p>The existing motorized louver adjacent to the generator cooling damper shall be repaired as necessary and interlocked with the operation of the generator and the boiler burner.</p> <p>To facilitate the installation and allow for building heating during construction without the use of a temporary boiler, the new steam boiler may be relocated to an appropriate location as selected by the contractor provided it is installed per the manufacturer’s recommendations and the installation is pursuant to code.</p> <p>The insulated flue liner as prescribed in the performance specification shall be changed to a UL listed stainless steel liner with condensate and neutralizer as recommended and approved by the boiler manufacturer.</p>
13.	<p><b>Add Alternate:</b></p> <p>Each contractor shall (at their option) provide an add alternate to their schedule of values to connect and convert the existing propane fired generator to natural gas. This line item shall include conversion and start-up to be performed by a factory authorized representative of the generator manufacturer.</p>
14.	<p><b>Attachments:</b></p> <p>Pre-Bid Meeting Sign-In Sheet.</p>




---

Mitch Daigle  
VP & Senior Project Manager  
Cordjia Capital Projects Group, LLC

<b>Client:</b>	City of Auburn, Maine
<b>Project:</b>	Hasty Community Center Steam Boiler Replacement Project – Bid # 2014-017

	Name	Company Name	Email Address	Phone Number
1.	Derek Boulanger	City of Auburn, Facilities Manager	dboulanger@auburnmaine.gov	207-333-6601, ext. 1135
2.	Mitchell Daigle	Cordjia Capital Projects Group	mdaigle@cordjiacpg.com	207-236-9970
3.	Travis Wheeler	Mechanical Services, Inc.	trwheeler@mechanicalservices.com	626-0822
4.	Runt Magnusson	M.S.E.	RUNT & MECHANICAL SYSTEMS ENCL.COM	846-1441
5.	Robert Berry	E.C.S.	rberry@ecersincorp.com	603-828-2994
6.	Gary Perry	Sullivan and Merritt	gperry@sullivanandmerritt.com	207-745-3877
7.	Mark Mason	Nason Mechanical	mym@nasonmechanical.com	782-0727
8.	Mark Bouchard	Nason		782-0727
9.				
10.				