

**ADDENDUM NO. 1**

TO

CITY OF AUBURN, MAINE

2025 North Auburn Road Pavement Resurfacing MPI Project BID#2025-036

**DATE: 5/20/2025**

*This addendum amends and /or supplements the bid documents as indicated below. Only these items alter the bid documents. Any verbal discussions or responses are hereby declared null and void. Please acknowledge this addendum on the attached Bid Proposal Form.*

---

**Q: Please clarify the quantity for 403.209 and the spot repairs.**

**A:** This item is inclusive of the driveway matches (90ton) and for the 12.5mm within spot repairs at a length of 2,900' on both sides of the road by 3' width with worst case of 4" depth repair (430ton).

**Q: Please review the schedule of values for 403.213.**

**A:** Item 403.213 is replaced on the attached Bid Form as 403.210 for the 9.5mm surface item. The 12.5mm item will be used, but paid for under the 403.209 pay item.

**Q: Are there specific locations for 202.20 to be used?**

**A:** There is significant passenger wheel path deterioration that the City prefers to repair prior to resurfacing. Most of these locations are between West Auburn Road and Hersey Hill Road.

**Q: Could the City extend the bid date by a week?**

**A:** Yes the new bid opening date is June 5<sup>th</sup> at 2:00pm at City Hall.

**Q: Could the City extend the project completion date into 2026?**

**A:** No, the City would like this project completed in 2025.

**Q: Is the City going to require police for any traffic control on this project?**

**A:** No.

**Q: Is QC testing required for the paving?**

**A:** Please carry QC for the 9.5mm 403.210 Item.

**Q: Will the City allow for non-spec ¾" gravel to be used for the shoulders?**

**A:** The City will allow for some non-spec ¾" gravels after submittal review.

**Q: What is the estimate?**

**A:** \$330,000.00.

**Q: Will the question deadline be pushed with the new bid opening date?**

**A:** Yes, questions are due by Friday, May 30<sup>th</sup> at 4:00pm.

**BASE BID FORM – ADDENDUM #1**

<b>Bid Item</b>	<b>Description</b>	<b>Unit</b>	<b>Qty</b>	<b>Unit Cost</b>	<b>Total Cost</b>
202.20	Remove Bituminous Surface	SY	2,000		
202.203	Pavement Butt Joints	SY	300		
304.14	Aggregate Base Course – Type A (DW)	TON	100		
304.141	¾" Type A Shoulder Gravel	TON	450		
403.209	Hot Mix Asphalt, Hand Work	TON	520		
403.210	Hot Mix Asphalt, 9.5mm Surface	TON	1,350		
403.211	Hot Mix Asphalt, 9.5mm Shim	TON	520		
409.15	Bituminous tack coat, applied	GAL	600		
615.08	Loam and Seed	SY	100		
627.733	4" Double Yellow Painted Pavement Marking Line	LF	7,300		
652.39	Traffic Control	LS	1		
659.10	Mobilization	LS	1		
			<b>TOTAL</b>		

Company Name: \_\_\_\_\_

Signed by: \_\_\_\_\_

Title: \_\_\_\_\_

Print Name: \_\_\_\_\_

Address: \_\_\_\_\_

Tel. # \_\_\_\_\_

Date: \_\_\_\_\_

Addendum Acknowledged:

# \_\_\_\_\_ Date \_\_\_\_\_

# \_\_\_\_\_ Date \_\_\_\_\_

# \_\_\_\_\_ Date \_\_\_\_\_

## BID PROPOSAL FORM

Due: Thursday, June 5th, 2025

To: City of Auburn  
Purchasing Department  
60 Court Street  
Auburn, ME 04210

The undersigned individual/firm/business guarantees this price for thirty days (30) from the proposal due date. The undersigned submits this proposal without collusion with any other person, individual, or firm or agency. The undersigned ensures the authority to act on behalf of the corporation, partnership or individual they represent; and has read and agreed to all of the terms, requests, or conditions written herein by the City of Auburn, Maine.

By signing this form, the firm listed below hereby affirms that its bid meets the minimum specifications and standards as listed above.

Signature \_\_\_\_\_ Company \_\_\_\_\_  
Name (print) \_\_\_\_\_ Title \_\_\_\_\_  
Phone Number \_\_\_\_\_  
Address \_\_\_\_\_  
Email Address \_\_\_\_\_

STATE OF MAINE

\_\_\_\_\_, SS.

Date: \_\_\_\_\_

Personally, appeared \_\_\_\_\_ and acknowledged the foregoing instrument to be his/her free act and deed in his/her capacity and the free act and deed of said company.

Notary Public \_\_\_\_\_

Print Name \_\_\_\_\_

Commission Expires \_\_\_\_\_

