ADDENDUM #2

WOODBURY BRACKETT MUNICIPAL GARAGE, 2nd FLOOR RESTROOM RENOVATION PROJECT, BID NO. 2018-020

City of Auburn, Maine March 5, 2018

Please include the following recommended changes:

GENERAL ITEMS:

N/A

CHANGES TO THE SPECIFICATIONS:

N/A

CHANGES TO THE DRAWINGS:

N/A

CLARIFICATIONS:

1. It was confirmed that the two bath rooms on the 2nd floor have exhaust which is located on the roof and is tied in with the men's bathroom and locker room on the 1st floor. This exhaust ventilation shall be disconnected and capped as required to serve only the men's bathroom and locker room on the 1st floor. The new 2nd floor men's room, woman's room and janitor closet shall have new code compliant exhaust ventilation in accordance with ASHRAE 62.1.

ATTACHMENTS:

N/A

END OF ADDENDUM #2