

ADDENDUM NO. 1  
TO  
CITY OF AUBURN, MAINE  
2019 MPI OVERLAY PROJECT  
October 16, 2019

This addendum amends and /or supplements the bid documents as indicated below. Only these items alter the bid documents.

**Clarifications to the Bid Documents:**

The following changes have been made to the Bid Documents:

Question: Can 1-1/2" Type A be used for shoulder gravel?

Answer: Gravel shall have a maximum aggregate size of 3/4" and sourced from a quarry. Material shall be approved by the Engineer.

Question: Is the plan to match driveway aprons after placing main line to find an appropriate butt joint match into each driveway?

Answer: All milling shall be completed prior to paving. Match lines will be determined in the field prior to paving.

Question: The tack coat quantity seems too high.

Answer: This quantity is based on a range of 0.02 to 0.04 gal/sy and 0.04 was used for the estimate.