



Auburn Fire Department

David N. O'Connell | Fire Inspector/Fire Investigator

550 Minot Avenue | Auburn, Maine 04210

doconnell@auburnmaine.gov | 207.333.6633 ext. 6

April 28, 2021

Minimum fire department requirements that need to be taken into consideration before plans are submitted to the city of Auburn for review by the fire department. This includes, but is not limited to:

- Fire department access
- Turning radius
- Fire lanes
- Grade of roads
- Hydrant locations
- Fire flow requirements for structure
- Fire department connections (4" Storz) for the sprinkler system. (If applicable)
- Appropriate means of egress
- Fire and life safety plans included with the blueprints. This should include (if applicable) fire extinguisher locations, fire alarm system, knox box location, travel distances, exit signs, emergency lights, fire alarm devices.

All life safety features will meet Maine State Statute, local ordinances, and the National Fire Protection Association (NFPA) codes and standards adopted by the state and municipality.

Sincerely,

David N. O'Connell
Fire Prevention Officer