

ADDENDUM NO. 1
TO
CITY OF AUBURN, MAINE
2016 SIDEWALK RECONSTRUCTION PROJECT
October 7, 2016

This addendum amends and /or supplements the bid documents as indicated below. Only these items alter the bid documents. Any verbal discussions or responses are hereby declared null and void. Please acknowledge this addendum on page 6 of 30 of the Bid Document.

Clarifications to the Bid Documents:

The following changes have been made to the Bid Documents:

Question: Does the entire project have to be completed by December 2nd 2016 excluding seed and surface? Can it be reconstructed in sections up to the date and completed in the spring of 2017?

Answer: The intent is to complete as much of the project as possible while following the MaineDOT Standard Specifications 401.06 Weather and Seasonal Limitations. December 2nd is an estimated date for weather limitations. The portion not completed in the 2016 season shall be completed in the spring of 2017. Completing only gravel in driveways and sidewalks will be unacceptable prior to winter demobilization. Public Works' snow maintenance requires paved surfaces.

Question: What is the City's budget for this project?

Answer: \$277,000.00

Question: Are you planning on installing MDOT Item 608.26 Curb Ramp Detectable Warning Field on this project?

Answer: This Item is not intended for this project as they are currently installed. Butt joints shall be made at the recently paved portions from their prior installation.

Updated Resident Responses to tree removal:

499 Turner Street: Wants tree sections 14" or less in diameter. - 2 trees
491 Turner Street: Wants the wood from the trees. - 2 trees
471 Turner Street: Wants the wood from the tree. - 1 tree